



1672 Donlon Street  
Ventura, CA 93003  
Local 805 654-6977  
Fax 805 654-6979  
[www.jdscivil.com](http://www.jdscivil.com)

VPD01.4558  
Wednesday, December 20, 23023

To Whom it May Concern,


Attention to bidders of Ventura Harbor Public Boat Wash Station Replacement Project 1400 Anchors  
Way Dr., Ventura, California

**Addendum No. 2: Answers to pre-bid meeting questions**

During the pre-bid meeting on December 7, 2023 there were several questions asked by prospective bidders. This document is to answer questions asked at the pre-bid meeting.

1. Q: Length of new concrete?  
A: 30' Long by 14.75' Wide
2. Q: Do we know the existing concrete thickness?  
A: We do not.
3. Q: IS the contractor to provide new trash cans?  
A: Yes
4. Q: Is there a detail for the logo as requested on the trashcan?  
A: The logo will need to be 12"x12" with the logo electronically provided by the Ventura Port District. The logo is to be on aluminum and affixed to two sides of each trash can.

Thank you for attending the pre-bid meeting, and we look forward to you bids.



James C. McCoskey, P.E.  
Senior Civil Engineer  
Jensen Design & Survey, Inc.